CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.   3225-0368:115   Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Pottorff, 2824 N. Sylvania Ave., Fort Worth, TX 76111
Contact: Michael Beaver (817) 831-7038

DESIGN: Models FD-150, FSD-151 and FSD-152 single and multi blade type fire rated dampers. Unit is constructed of No. 20 Gage galvanized steel frame, No. 24 gage galvanized steel blades. Refer to listee's data sheet for detailed product description and operational considerations. Sizes of dampers are as follow:

Model	Construction	Width, Inch		Height, Inch	
		Min.	*Max.*	*Min.*	*Max.*
FSD	Single section	8	30	8	50
	Multiple section	8	90	8	100
FD	Single section	8	30	8	50
	Multiple section	8	90	8	100

RATING: 1-1/2 hour

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as 1-1/2 hour fire-rated dampers for use in heating, ventilating and air conditioning systems passing through fire resistive walls and partitions. *Intended for use with approved damper operators. For vertical installation installations only.

NOTE: For leakage classification, refer to CSFM Listing No. 3230-368:116

*Rev. 09-11-01

Date Issued: **MAY 15, 2002**   *Listing Expires June 30, 2003*

*A*uthorized *By:*   **DIANE K. AREND**, *Senior Deputy*
Program Manager